

Splicing method: L type splicing: Straight line splicing: Install the first luminaire and fix the L After the first luminaire is installed put the type positioning bracket with screws. positioning bracket into the slot, fix the Install the second luminaire into to L type positioning bracket with screws, then bracket, fix the luminaire and connect the connect the second luminaire with wires. the first one together. 2 L type splicing: 3 L type splicing: Torn off the two piece sheets of the Take off the end cover of the last luminaire. and fix the plug in the accessories package to connector that the wires will through, and then connected the wires in the connector, the luminaire. fix the connector with screws.

Notice:

- $1_{\,\mathrm{V}}\,$ Please operate the wire connection, luminaire installation under the condition of power off.
- 2. The maximum total length of the splicing shall not exceed 10 meters.
- 3、T-shaped splicing, cross-shaped splicing can be spliced in L-shaped splicing.
- 4. The specific appearance is subject to the real product !



- Use only drivers that comply with IEC or CE safety standards.
- Check if the power supply match with the luminaire.
- Must consider the maximum current value displayed on the label of the luminaire.
 The voltage displayed on the luminaire is not used to select the constant voltage driver, but
- the voltage covered by the selected constant current driver.
- Take suitable ESD measures to avoid touching bare conductors.
- LED chips can be damaged if be in touch with chemical material or gas. Therefore, it is not allowed to clean the LED housing or luminaire by chemicals.
- The following items are confirmed to have negative impact on the performance of the luminaire, avoid to keep luminaire in the same circumstance with them.
- Methyl acetate or ethyl acetate (i.e., nail polish remover) Cyanoacrylates (i.e., "Superglue") Glvcol ethers (including Radio Shack ® Precision Electronics
- Glycol ethers (including Radio Shack ® Precision Electronic
- Cleaner dipropylene glycol monomethyl ether) Formaldehyde or butadiene (including Ashland PLIOBOND ® adhesive)
- Dymax 984-LVUF conformal coating
- Loctite Sumo Glue, Loctite 384 adhesive, Loctite 7387 activator Gorilla Glue, Bleach, Bleach-containing cleaners, sprays

- Remove the insulation material from the luminaire or provide enough space so that the temperature raising will not overpass the limited TC.

- LED chip is very sensitive to switching transients, therefore, LED lamps and appliances must be connected after power cut off, no hotswappable.

- Recommends using the driver indicated on the luminaire manual.
- Must consider the polarity of the product.
- -If the external flexible cable or cord of this lamp is damaged, the cord should be replaced by the manufacturer or its service agent or a similarly gualified person

-The light source in this lamp should be replaced by the manufacturer or its service agent or a similarly qualified person

3.